# Safety Data Sheet according to Regulation (EU) 2015/830





# Propane

Date of issue: 01/04/2015 SDS reference: ALM/SDS/107 Supersedes: 01/04/2015

Revision date: 20/12/2019

Version: 1.0



# **Danger**

# SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Trade name : Propane SDS no : ALM/SDS/107

1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use.

Contact supplier for more information on uses.

Uses advised against : Consumer use.

1.3. Details of the supplier of the safety data sheet

Company identification : AIR LIQUIDE MALAYSIA SDN. BHD.

Lot PT 2317, No. 21, Jalan PTB 1 Kawasan Perindustrian Tangga Batu, Mukim Sungai Udang,

76400 Melaka - Malaysia

1.4. Emergency telephone number

Emergency telephone number : +606-3513512

# **SECTION 2: Hazards identification**

#### 2.1. Classification of the substance or mixture

# Classification according to Regulation (EC) No. 1272/2008 [CLP]

Physical hazards Flammable gases, Category 1 H220

> Gases under pressure: Liquefied gas H280 Acute toxicity (inhalation:gas) Category 4 H332

#### 2,2, Label elements

Signal word (CLP)

Health hazards

# Labelling according to Regulation (EC) No. 1272/2008 [CLP]

Hazard pictograms (CLP)







: Danger

Hazard statements (CLP) : H220 - Extremely flammable gas.

H280 - Contains gas under pressure; may explode if heated.

H332 - Harmful if inhaled.

Precautionary statements (CLP)

- Prevention: P210 - Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No

smoking.

P260 - Do not breathe gas, vapours.

AIR LIQUIDE MALAYSIA SDN. BHD. EN (English) SDS Ref.: ALM/SDS/107 1/11 Lot PT 2317, No. 21, Jalan PTB 1

Kawasan Perindustrian Tangga Batu, Mukim Sungai Udang, 76400 Melaka

Malaysia



SDS Ref.: ALM/SDS/107

- Response : P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely.

P381 - In case of leakage, eliminate all ignition sources.

P304+P340+P315 - IF INHALED : Remove person to fresh air and keep comfortable for

breathing. Get immediate medical advice.

- Storage : P403 - Store in a well-ventilated place.

#### 2.3. Other hazards

: Contact with liquid may cause cold burns/frostbite.

# **SECTION 3: Composition/information on ingredients**

3.1. Substances : Not applicable

#### 3.2. Mixtures

Name	Product identifier	%	Classification according to Regulation (EC) No. 1272/2008 [CLP]
Propane	(CAS-No.) 74-98-6 (EC-No.) 200-827-9 (EC Index-No.) 601-003-00-5 (REACH-no) 01-2119486944-21	100	Flam. Gas 1, H220 Press. Gas (Liq.), H280

# **SECTION 4: First aid measures**

# 4.1. Description of first aid measures

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Perform cardiopulmonary resuscitation if breathing

SDS Ref.: ALM/SDS/107

stopped.

- Skin contact : In case of frostbite spray with water for at least 15 minutes. Apply a sterile dressing. Obtain

medical assistance.

- Eye contact : Immediately flush eyes thoroughly with water for at least 15 minutes.

- Ingestion : Ingestion is not considered a potential route of exposure.

# 4.2. Most important symptoms and effects, both acute and delayed

: Refer to section 11.

# 4.3. Indication of any immediate medical attention and special treatment needed

: Obtain medical assistance.

# **SECTION 5: Firefighting measures**

#### 5.1. Extinguishing media

Suitable extinguishing media
 Unsuitable extinguishing media
 Carbon dioxide.

Do not use water jet to extinguish.

# 5.2. Special hazards arising from the substance or mixture

Specific hazards : Exposure to fire may cause containers to rupture/explode.

Hazardous combustion products : Carbon monoxide.

# 5.3. Advice for firefighters



SDS Ref.: ALM/SDS/107

Specific methods : Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive re-

ignition may occur. Extinguish any other fire.

Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering sewers and

drainage systems.

If possible, stop flow of product.

Use water spray or fog to knock down fire fumes if possible.

Move containers away from the fire area if this can be done without risk.

Special protective equipment for fire fighters : Wear gas tight chemically protective clothing in combination with self contained breathing

apparatus.

Standard EN 943-2: Protective clothing against liquid and gaseous chemicals, aerosols and

solid particles. Gas-tight chemical protective suits for emergency teams.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask.

#### **SECTION 6: Accidental release measures**

#### 6.1. Personal precautions, protective equipment and emergency procedures

: Try to stop release.

Evacuate area.

Monitor concentration of released product.

Consider the risk of potentially explosive atmospheres.

Wear self-contained breathing apparatus when entering area unless atmosphere is proved to

be safe.

Eliminate ignition sources.

Ensure adequate air ventilation.

Prevent from entering sewers, basements and workpits, or any place where its accumulation

SDS Ref.: ALM/SDS/107

can be dangerous.

Act in accordance with local emergency plan.

Stay upwind.

6.2. Environmental precautions

: Try to stop release.

#### 6.3. Methods and material for containment and cleaning up

: Ventilate area.

6.4. Reference to other sections

: See also sections 8 and 13.

# **SECTION 7: Handling and storage**

#### 7.1. Precautions for safe handling



SDS Ref.: ALM/SDS/107

Safe use of the product

: Assess the risk of potentially explosive atmospheres and the need for explosion-proof equipment.

Purge air from system before introducing gas.

Take precautionary measures against static discharge.

Keep away from ignition sources (including static discharges).

Consider the use of only non-sparking tools. Ensure equipment is adequately earthed.

Avoid exposure, obtain special instructions before use.

The product must be handled in accordance with good industrial hygiene and safety procedures.

Only experienced and properly instructed persons should handle gases under pressure.

Consider pressure relief device(s) in gas installations.

Ensure the complete gas system was (or is regularily) checked for leaks before use.

Do not smoke while handling product.

Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt.

Avoid suck back of water, acid and alkalis.

Do not breathe gas.

Avoid release of product into work area.

Safe handling of the gas receptacle : Refer to supplier's container handling instructions.

Do not allow backfeed into the container.

Protect cylinders from physical damage; do not drag, roll, slide or drop.

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders.

Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use.

If user experiences any difficulty operating cylinder valve discontinue use and contact supplier.

Never attempt to repair or modify container valves or safety relief devices.

Damaged valves should be reported immediately to the supplier.

 $\label{thm:container} \textbf{Keep container valve outlets clean and free from contaminants particularly oil and water.}$ 

Replace valve outlet caps or plugs and container caps where supplied as soon as container is disconnected from equipment.

Close container valve after each use and when empty, even if still connected to equipment.

Never attempt to transfer gases from one cylinder/container to another.

Never use direct flame or electrical heating devices to raise the pressure of a container.

Do not remove or deface labels provided by the supplier for the identification of the cylinder contents.

Suck back of water into the container must be prevented.

Open valve slowly to avoid pressure shock.

# 7.2. Conditions for safe storage, including any incompatibilities

: Segregate from oxidant gases and other oxidants in store.

All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.

Observe all regulations and local requirements regarding storage of containers.

Containers should not be stored in conditions likely to encourage corrosion.

Container valve guards or caps should be in place.

Containers should be stored in the vertical position and properly secured to prevent them from falling over.

Stored containers should be periodically checked for general condition and leakage.

Keep container below 50°C in a well ventilated place.

Store containers in location free from fire risk and away from sources of heat and ignition.

Keep away from combustible materials.



SDS Ref.: ALM/SDS/107

#### 7.3. Specific end use(s)

: None

# **SECTION 8: Exposure controls/personal protection**

#### 8.1. Control parameters

Propane (74-98-6)				
OEL : Occupational Exposure Limits				
ACGIH	Remark (ACGIH)	Simple Asphyxiant		
	Regulatory reference	ACGIH 2017		

DNEL (Derived-No Effect Level) : None established.

PNEC (Predicted No-Effect Concentration) : None established.

#### 8.2. Exposure controls

#### 8.2.1. Appropriate engineering controls

: Provide adequate general and local exhaust ventilation.

Product to be handled in a closed system.

Consider the use of a work permit system e.g. for maintenance activities. Gas detectors should be used when toxic gases may be released.

Systems under pressure should be regularily checked for leakages.

Ensure exposure is below occupational exposure limits (where available).

# 8.2.2. Individual protection measures, e.g. personal protective equipment

: A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk. The

following recommendations should be considered:

PPE compliant to the recommended EN/ISO standards should be selected.

• Eye/face protection : Wear goggles when transfilling or breaking transfer connections.

Standard EN 166 - Personal eye-protection - specifications.

· Skin protection

- Hand protection : Wear working gloves when handling gas containers.

Standard EN 388 - Protective gloves against mechanical risk.

- Other : Consider the use of flame resistant anti-static safety clothing.
Standard EN ISO 14116 - Limited flame spread materials.

Standard EN 1149-5 - Protective clothing: Electrostatic properties.

Wear safety shoes while handling containers.

Standard EN ISO 20345 - Personal protective equipment - Safety footwear.

• Respiratory protection : Gas filters may be used if all surrounding conditions e.g. type and concentration of the

contaminant(s) and duration of use are known.

Use gas filters with full face mask, where exposure limits may be exceeded for a short-term

period, e.g. connecting or disconnecting containers.

Consult respiratory device supplier's product information for the selection of the appropriate

device.

Gas filters do not protect against oxygen deficiency.

Standard EN 14387 - Gas filter(s), combined filter(s) and standard EN136, full face masks.

Keep self contained breathing apparatus readily available for emergency use.

Self contained breathing apparatus is recommended, where unknown exposure may be

expected, e.g. during maintenance activities on installation systems.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask.



SDS Ref.: ALM/SDS/107

• Thermal hazards : None in addition to the above sections.

8.2.3. Environmental exposure controls

: Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for

specific methods for waste gas treatment.

# **SECTION 9: Physical and chemical properties**

#### 9.1. Information on basic physical and chemical properties

Appearance

Physical state at 20°C / 101 3kPa
 Gas

Colour
 Mixture contains one or more component(s) which have the following colour(s):

Colourless.

Odour : There may be no odour warning properties, odour is subjective and inadequate to warn of

overexposure.

Mixture contains one or more component(s) which have the following odour:

Stenchant often added. Sweetish.

Odour threshold : Odour threshold is subjective and inadequate to warn of overexposure.

pH : Not applicable for gases and gas mixtures.

Melting point / Freezing point : .Not applicable for gas mixtures.

Boiling point : .Not applicable for gas mixtures.

Flash point : Not applicable for gases and gas mixtures.

Evaporation rate : Not applicable for gases and gas mixtures.

Flammability (solid, gas) : Extremely flammable gas.

Explosive limits : Flammability range not available.

Vapour pressure [20°C] : Not known.

Vapour density : Not applicable.

Relative density, gas (air=1) : Heavier than air.

Partition coefficient n-octanol/water (Log Kow) : .Not applicable for gas mixtures.

Auto-ignition temperature : Not known.

Decomposition temperature : Not applicable.

Viscosity, kinematic : No reliable data available.

Explosive properties : Not applicable.

Oxidising properties : Not applicable.

9.2. Other information

Molar mass : .Not applicable for gas mixtures.

Other data : Gas/vapour heavier than air. May accumulate in confined spaces, particularly at or below

ground level.

# **SECTION 10: Stability and reactivity**

10.1. Reactivity

: No reactivity hazard other than the effects described in sub-sections below.

SDS Ref.: ALM/SDS/107

10.2. Chemical stability

: Stable under normal conditions.



SDS Ref.: ALM/SDS/107

10.3. Possibility of hazardous reactions

: Can form explosive mixture with air.

May react violently with oxidants.

10.4. Conditions to avoid

: Keep away from heat/sparks/open flames/hot surfaces. - No smoking.

Avoid moisture in installation systems.

10.5. Incompatible materials

: Air, Oxidisers.

For additional information on compatibility refer to ISO 11114.

10.6. Hazardous decomposition products

: Under normal conditions of storage and use, hazardous decomposition products should not be

SDS Ref.: ALM/SDS/107

produced.

# **SECTION 11: Toxicological information**

# 11.1. Information on toxicological effects

Acute toxicity : Harmful if inhaled.

Propane (74-98-6)	
LC50 inhalation rat (ppm)	20000 ppm/4h
Skin corrosion/irritation	: No known effects from this product.
Serious eye damage/irritation	: No known effects from this product.
Respiratory or skin sensitisation	: No known effects from this product.
Germ cell mutagenicity	: No known effects from this product.
Carcinogenicity	: No known effects from this product.
Toxic for reproduction : Fertility	: No known effects from this product.
Toxic for reproduction : unborn child	: No known effects from this product.
STOT-single exposure	: No known effects from this product.
STOT-repeated exposure	: No known effects from this product.
Aspiration hazard	: Not applicable for gases and gas mixtures.

# **SECTION 12: Ecological information**

# 12.1. Toxicity

Assessment : Classification criteria are not met.

EC50 48h - Daphnia magna [mg/l] : No data available. EC50 72h - Algae [mg/l] : No data available. LC50 96 h - Fish [mg/l] : No data available.

Propane (74-98-6)	
EC50 48h - Daphnia magna [mg/l]	27.1 mg/l
EC50 72h - Algae [mg/l]	11,9 mg/l
LC50 96 h - Fish [mg/I]	49.9 mg/l

# 12.2. Persistence and degradability

Assessment : No data available.

12.3. Bioaccumulative potential

Assessment : No data available.



SDS Ref.: ALM/SDS/107

12.4. Mobility in soil

Assessment : Because of its high volatility, the product is unlikely to cause ground or water pollution.

Partition into soil is unlikely.

12.5. Results of PBT and vPvB assessment

Assessment : Not classified as PBT or vPvB.

12.6. Other adverse effects

Other adverse effects : No known effects from this product.

Effect on the ozone layer : None.

Effect on global warming : Contains greenhouse gas(es).

# **SECTION 13: Disposal considerations**

#### 13.1. Waste treatment methods

Contact supplier if guidance is required.

Do not discharge into areas where there is a risk of forming an explosive mixture with air.

Waste gas should be flared through a suitable burner with flash back arrestor.

Ensure that the emission levels from local regulations or operating permits are not exceeded.

Refer to the EIGA code of practice Doc.30 "Disposal of Gases", downloadable at

http://www.eiga.eu for more guidance on suitable disposal methods.

Must not be discharged to atmosphere.

Return unused product in original cylinder to supplier.

List of hazardous waste codes (from Commission Decision 2000/532/EC as amended)

: 16 05 04 \*: Gases in pressure containers (including halons) containing hazardous substances.

13.2. Additional information

: External treatment and disposal of waste should comply with applicable local and/or national

SDS Ref.: ALM/SDS/107

regulations.

# **SECTION 14: Transport information**

#### 14.1. UN number

UN-No. : 1965

14.2. UN proper shipping name

Transport by road/rail (ADR/RID) HYDROCARBON GAS MIXTURE, LIQUEFIED, N.O.S. (Propane)

Transport by air (ICAO-TI / IATA-DGR) Hydrocarbon gas mixture, liquefied, n.o.s. (Propane)

Transport by sea (IMDG) HYDROCARBON GAS MIXTURE, LIQUEFIED, N.O.S. (Propane)

14.3. Transport hazard class(es)

Labelling



2.1 : Flammable gases.

Transport by road/rail (ADR/RID)

Class : 2 Classification code : 2F



SDS Ref.: ALM/SDS/107

Hazard identification number : 23

Tunnel Restriction : B/D - Tank carriage : Passage forbidden through tunnels of category B, C, D and E. Other

carriage: Passage forbidden through tunnels of category D and E

Transport by air (ICAO-TI / IATA-DGR)

Class / Div. (Sub. risk(s)) : 2.1

Transport by sea (IMDG)

Class / Div. (Sub. risk(s)) : 2.1
Emergency Schedule (EmS) - Fire : F-D
Emergency Schedule (EmS) - Spillage : S-U

14.4. Packing group

Transport by road/rail (ADR/RID) : Not applicable
Transport by air (ICAO-TI / IATA-DGR) : Not applicable
Transport by sea (IMDG) : Not applicable

14.5. Environmental hazards

Transport by road/rail (ADR/RID) : None.

Transport by air (ICAO-TI / IATA-DGR) : None.

Transport by sea (IMDG) : None.

14.6. Special precautions for user

Packing Instruction(s)

Transport by road/rail (ADR/RID) : P200

Transport by air (ICAO-TI / IATA-DGR)

Passenger and Cargo Aircraft : Forbidden.
Cargo Aircraft only : 200.
Transport by sea (IMDG) : P200

Special transport precautions : Avoid transport on vehicles where the load space is not separated from the driver's

event of an accident or an emergency.

compartment.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the

SDS Ref.: ALM/SDS/107

Before transporting product containers:
- Ensure there is adequate ventilation.
- Ensure that containers are firmly secured.
- Ensure cylinder valve is closed and not leaking.

- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.

- Ensure valve protection device (where provided) is correctly fitted.

#### 14.7. Transport in bulk according to Annex II of Marpol and the IBC Code

: Not applicable.

# **SECTION 15: Regulatory information**

# 15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

# **EU-Regulations**

Restrictions on use : None.

Seveso Directive : 2012/18/EU (Seveso III) : Covered.



SDS Ref.: ALM/SDS/107

National regulations

National legislation : Ensure all national/local regulations are observed.

15.2. Chemical safety assessment

: A CSA does not need to be carried out for this product.

# **SECTION 16: Other information**

Indication of changes Revised safety data sheet in accordance with commission regulation (EU) No 2015/830.

Abbreviations and acronyms : ATE - Acute Toxicity Estimate CLP - Classification Labelling Packaging Regulation; Regulation (EC) No 1272/2008

REACH - Registration, Evaluation, Authorisation and Restriction of Chemicals Regulation (EC)

No 1907/2006

EINECS - European Inventory of Existing Commercial Chemical Substances

CAS# - Chemical Abstract Service number PPE - Personal Protection Equipment

LC50 - Lethal Concentration to 50 % of a test population

RMM - Risk Management Measures

PBT - Persistent, Bioaccumulative and Toxic vPvB - Very Persistent and Very Bioaccumulative

STOT- SE: Specific Target Organ Toxicity - Single Exposure

CSA - Chemical Safety Assessment

EN - European Standard **UN - United Nations** 

ADR - European Agreement concerning the International Carriage of Dangerous Goods by

Road

IATA - International Air Transport Association

IMDG code - International Maritime Dangerous Goods

RID - Regulations concerning the International Carriage of Dangerous Goods by Rail

WGK - Water Hazard Class

STOT - RE: Specific Target Organ Toxicity - Repeated Exposure

: Ensure operators understand the flammability hazard.

Users of breathing apparatus must be trained. Ensure operators understand the toxicity hazard.

Further information Classification using data from databases maintained by the European Industrial Gases

Association (EIGA).

Classification in accordance with the calculation methods of Regulation (EC) 1272/2008 CLP.

# Full text of H- and EUH-statements

Training advice

Acute Tox. 4 (Inhalation:gas)	Acute toxicity (inhalation:gas) Category 4
Flam. Gas 1	Flammable gases, Category 1
Press. Gas (Liq.)	Gases under pressure : Liquefied gas
H220	Extremely flammable gas.
H280	Contains gas under pressure; may explode if heated.
H332	Harmful if inhaled.

DISCLAIMER OF LIABILITY

Before using this product in any new process or experiment, a thorough material compatibility

and safety study should be carried out.

Details given in this document are believed to be correct at the time of going to press.

Whilst proper care has been taken in the preparation of this document, no liability for injury or

damage resulting from its use can be accepted.



SDS Ref.: ALM/SDS/107

SDS Ref.: ALM/SDS/107